

01

OFFICIAL FILE

I.C.C. DOCKET NO. 01-0453
Complainant Exhibit No. 9

Witness _____
Date 11/9/01 Reporter TR

R. PORT OF UNMETERED GAS

Date 3-15-01 File No. #2Name VIRGINIA DIEHL Address 650 N. CENTRAL AVE Town CHGOEmployed By _____ Floor Loc. BSEType of Building: Multiple Dwelling ☐ Apartment ☐ House ☒ No. of Occupants _____

Square Mile Area _____

Owner VIRGINIA DIEHL Address 650 N CENTRAL AVE Telephone 773 626-6080

Owner _____ Address _____ Telephone _____

CONNECTION:

Rubber Hose ☐ Iron Fittings ☐ Fittings and Pipe ☒ Meter in Use ☐ Meter Removed ☐Meter Locked Off ☐ Meter Bar in Place ☒ Openings Protected ☒ Service Pipe Protected ☐Location of Connection Above Meter Header Connection Concealed? Yes ☐ No ☒Connection Installed by UNKNOWN

Approximate Time in Use: Occupant's Opinion _____ Inspector's Opinion _____

Was Connection Leaking? Yes ☐ No ☒ Was Gas Seen Burning? Yes ☒ No ☐ By Whom? M. ALDAYConnection Removed By P. MURRAY

APPLIANCES SUPPLIED:

Range ☒ Refrig. ☐ Automatic Water Heater ☒ Size 40 GAL BTU Rating 34 CH No. of Apts. Supplied HSC Other ☐Type Fuel Used for Heating GAS If Gas: CHP ☒ Circ. Heater ☐System: Hot Water ☒ Steam ☐ Warm Air ☐ BTU Rating 270 No. of Apts. Supplied LARGE HOUSE

METER INFORMATION:

Meter Number 1763276 Meter Location BSE Present Reading 9078 Date Meter Set _____

REMARKS: M. ALDAY ON PREMISES FOR #8 CALL. FOUND
DIVERSION FROM BLDG SERVICE TO CUSTOMER HOUSE
PIPING. UNMETERED GAS FROM BLDG-SERVICE TO
CUSTOMER HSE. PIPING. CONNECTION REMOVED AND
PROTECTED WITH 1" FACE WHEELING PLUG. ALL WAS
LEFT SECURED

Reported by P. MURRAY Date 3-15-01